

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0925

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

OH720 Analogue Addressable Multi Sensor Smoke Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Siemens Switzerland Ltd
Theilerstrasse 1a
CH-6300 Zug
Switzerland

Beijing Siemens Cerberus Electronics Limited
No. 1, Feng Zhi Dong Lu
Xi Bei Wang
Haidian District
Beijing 100094
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-7:2018 Smoke Detectors EN 54-17:2005 Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 22 February 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 22 February 2022

Issue Date: 22 February 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0925

OH720 Analogue Addressable Multi Sensor Smoke Detector with Short Circuit Isolator

Note:

1) Meets the requirements of EN 54-7 in the following sensitivities:

- 1 – Robust 3.5%/m
- 2 – Sensitive 2.5%/m

Bases:

DB721 Detector base with loop contact
DB722 Detector base
BA720 Base Attachment
BA721 Base Attachment Wet



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 22 February 2022

Issue Date: 22 February 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com