

Certificate of Product Approval

Certificate Number: 126bj

Issue: 03

Siemens Switzerland Ltd

Theilerstrasse 1a
CH-6300 Zug
Switzerland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors

FDT221

FDT241

(Refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

EN 54-17:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

10 March 2022

Date of Issue

6 November 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 126bj

Issue: 03

Siemens Switzerland Ltd

| Certified Product | Description | LPCB Ref.No. |
|-------------------|--|--------------|
| FDT221 | Analogue Addressable Rate of Rise Heat Detector with Short Circuit Isolator (FDB221, FDB222, FDB291, FDB292, FDB293 and FDB295 bases) Note: Meets EN 54-5:2017 + A1:2018 at Class A1R and BR. | 126bj/01 |
| FDT241 | Analogue Addressable Rate of Rise Heat Detector with Short Circuit Isolator (FDB221, FDB222, FDB291, FDB293 and FDB295 bases) Note: Meets EN 54-5:2017 + A1:2018 at Class A1R, A1S, BR and BS. | 126bj/02 |

Bases

| | |
|--------|---|
| FDB221 | Addressable Detector Base |
| FDB222 | Addressable Flat Detector Base |
| FDB291 | Base attachment for surface mount cable entry |
| FDB292 | Base attachment surface wet |
| FDB293 | Base Adaptor Humid |
| FDB295 | Base Adaptor Wet |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

10 March 2022

Date of Issue

6 November 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


