Systems Integration

Barber-Colman Network 8000 Driver: MicroZone II

Table 1. MicroZone II Point Map, Application Number: 5717.

Point	Type	Description	Range/Units[a b c]
1	LAO	ADDRESS	–
2	LAI	APPLICATION	–
3	LAI	ASD Device Type	–
4	LDO	EMS Control	Off/On
5	LDO	EMS DV1	Off/On
6	LDO	EMS DV2	Off/On
7	LDO	EMS DV3	Off/On
8	LDO	EMS DV4	Off/On
9	LDO	EMS DV5	Off/On
10	LDO	EMS DV6	Off/On
11	LDO	EMS DV7	Off/On
12	LDO	EMS DV8	Off/On
13	LAO	EMS AV1	–
14	LAO	EMS AV2	–
15	LAO	EMS AV3	–
16	LAO	EMS AV4	–
17	LAO	EMS AV5	–
18	LAO	EMS AV6	–
19	LAO	EMS AV7	–
20	LAO	EMS AV8	–
21	LDI	UI Digital Value 1	Off/On
22	LAI	UI Analog Value 1	–
23	LDI	UI Digital Value 2	Off/On
24	LAI	UI Analog Value 2	–
25	LDI	UI Digital Value 3	Off/On
26	LAI	UI Analog Value 3	–
27	LDI	UI Digital Value 4	Off/On

continued on next page...

Table 1. MicroZone II Point Map, Application Number: 5717. ***(continued)***

Point	Type	Description	Range/Units[a b c]
28	LAI	UI Analog Value 4	–
29	LDI	UI Digital Value 5	Off/On
30	LAI	UI Analog Value 5	–
31	LDI	UI Digital Value 6	Off/On
32	LAI	UI Analog Value 6	–
33	LDI	UI Digital Value 7	Off/On
34	LAI	UI Analog Value 7	–
35	LDI	UI Digital Value 8	Off/On
36	LAI	UI Analog Value 8	–
37	LDI	Digital Output 1	Off/On
38	LDI	Digital Output 2	Off/On
39	LDI	Digital Output 3	Off/On
40	LDI	Digital Output 4	Off/On
41	LDI	Digital Output 5	Off/On
42	LDI	Digital Output 6	Off/On
43	LDI	Digital Output 7	Off/On
44	LDI	Digital Output 8	Off/On
45	LAI	Analog Output 1	–
46	LAI	Analog Output 2	–
47	LAI	Analog Output 3	–
48	LAI	Analog Output 4	–
49	LDI	Window Digital Value 1	Off/On
50	LDI	Window Digital Value 2	Off/On
51	LDI	Window Digital Value 3	Off/On
52	LDI	Window Digital Value 4	Off/On
53	LDI	Window Digital Value 5	Off/On
54	LDI	Window Digital Value 6	Off/On
55	LDI	Window Digital Value 7	Off/On
56	LDI	Window Digital Value 8	Off/On
57	LAI	Window Analog Value 1	–
58	LAI	Window Analog Value 2	–
59	LAI	Window Analog Value 3	–
60	LAI	Window Analog Value 4	–
61	LAI	Window Analog Value 5	–

continued on next page...

Siemens Building Technologies, Inc.
Document No. 127-1499T

Table 1. MicroZone II Point Map, Application Number: 5717. ***(continued)***

Point	Type	Description	Range/Units[a] [b] [c]
62	LAI	Window Analog Value 6	–
63	LAI	Window Analog Value 7	–
64	LAI	Window Analog Value 8	–

[a] Values noted for LDIs and LDOs are in the following format: OFF text/ON text.

[b] This column indicates the value/range or engineering units or both if known.

[c] The default English value is not italicized. An italicized entry indicates an SI value.

Information in this document is based on specifications believed correct at the time of publication. The right is reserved to make changes as design improvements are introduced. Product or company names mentioned herein may be the trademarks of their respective owners.
© 2009 Siemens Building Technologies, Inc.

Siemens Building Technologies, Inc.
1000 Deerfield Parkway
Buffalo Grove, IL 60089-4513
U.S.A.