

Systems Integration

APOGEE[®] Open Processor with Sullair Driver: Supervisor II

Table 1. Supervisor II.

Point	Type	Description	Range/Units
00	LCTLR	Logical Point Group	—
01	LAI	Number Compressor ID	1 – 8
02	LAI	Application Number	5300
04	LDI	E Stop	On/Off
05	LDI	Manual Stop	On/Off
06	LDI	Remote Stop	On/Off
07	LDI	Standby	On/Off
08	LDI	Starting (during Wye-Delta time)	On/Off
09	LDI	Unloaded	On/Off
10	LDI	Loaded	On/Off
11	LDI	Trim	On/Off
12	LDI	Full Load	On/Off
13	LDI	Fault Indicator	On/Off
14	LDO	Stop Command	On/Off
15	LDO	Unload Command	On/Off
16	LDO	Load (Modulate) Command	On/Off
17	LDO	Full Load Command	On/Off
18	LDO	Trim Command	On/Off
19	LDO	E-Stop Command	On/Off
20	LDI	Auto Run Mode	On/Off
21	LDI	Continuous Run Mode	On/Off
22	LDI	Remote Start/Stop Enabled	On/Off
23	LAI	Run Hours	—
24	LAI	Run Time	—
25	LAI	Capacity	0 – 10,000

continued on next page...

Table 1. Supervisor II.

Point	Type	Description	Range/Units
26	LAI	Loaded Time	—
27	LAI	P1 Pressure	—
28	LAI	P2 Pressure	—
29	LDO	LCTLR Day Night Control	Not Used
30	LAI	P3 Pressure	—
31	LAI	P4 Pressure	—
32	LAI	T1 Temperature	—
33	LAI	T2 Temperature	—
34	LAI	T3 Temperature	—
35	LAI	T4 Temperature	—
36	LAI	T5 Temperature	—
37	LAI	T6 Temperature	—
38	LDI	P1 Shutdown	On/Off
39	LDI	P2 Shutdown	On/Off
40	LDI	P3 Shutdown	On/Off
41	LDI	P4 Shutdown	On/Off
42	LDI	DP1 Shutdown	On/Off
43	LDI	DP2 Shutdown	On/Off
44	LDI	DP3 Shutdown	On/Off
45	LDI	T1 Shutdown	On/Off
46	LDI	T2 Shutdown	On/Off
47	LDI	T3 Shutdown	On/Off
48	LDI	T4 Shutdown	On/Off
49	LDI	T5 Shutdown	On/Off
50	LDI	T6 Shutdown	On/Off
51	LDI	Output 1	On/Off
52	LDI	Output 2	On/Off
53	LDI	Output 3	On/Off
54	LDI	Output 4	On/Off
55	LDI	Output 5	On/Off
56	LDI	Output 6	On/Off
57	LDI	Output 7	On/Off
58	LDI	Output 8	On/Off
59	LDI	Output 9	On/Off

continued on next page...

Table 1. Supervisor II.

Point	Type	Description	Range/Units
60	LDI	Output 10	On/Off
61	LDI	Input 1 Shutdown	On/Off
62	LDI	Input 2 Shutdown	On/Off
63	LDI	Input 3 Shutdown	On/Off
64	LDI	Input 4 Shutdown	On/Off
65	LDI	Input 5 Shutdown	On/Off
66	LDI	Input 6 Shutdown	On/Off
67	LDI	Input 7 Shutdown	On/Off
68	LDI	Input 8 Shutdown	On/Off
69	LDI	Input 9 Shutdown	On/Off
70	LDI	Input 10 Shutdown	On/Off
71	LDI	Input 1	On/Off
72	LDI	Input 2	On/Off
73	LDI	Input 3	On/Off
74	LDI	Input 4	On/Off
75	LDI	Input 5	On/Off
76	LDI	Input 6	On/Off
77	LDI	Input 7	On/Off
78	LDI	Input 8	On/Off
79	LDI	Input 9	On/Off
80	LDI	Input 10	On/Off
99	LDI	Communication Failure	On/Off

Information in this document is based on specifications believed correct at the time of publication. The right is reserved to make changes as design improvements are introduced. Other product or company names mentioned herein may be the trademarks of their respective owners.
© 2002 Siemens Building Technologies, Inc.

Siemens Building Technologies, Inc.
1000 Deerfield Parkway
Buffalo Grove, IL 60089-4513
U.S.A.

Printed in the U.S.A.
Document No. 127-0534
Page 4 of 4