BRE Global

UK Approved Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance

0832-UKCA-CPR-F0901

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

FDCIO221 Analogue Addressable Input / Output Module with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of:

Siemens Switzerland Ltd
Theilerstrasse 1a
CH-6300 Zug
Switzerland

and produced in the manufacturing plant(s):

Beijing Siemens Cerberus Electronics Limited
No.1, Feng Zhi Dong Lu
Xi Bei Wang
Haidian District
Beijing 100094
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-17:2005 Short Circuit Isolators
EN 54-18:2005 Input / Output Devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 12 May 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 12 May 2022

Issue Date: 12 May 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

© BRE Global Limited, 2021

BRE Global

UK Approved Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0901

FDCIO221 Analogue Addressable Input / Output Module with Short Circuit Isolator

Note:
Approved when used with the FDCH221

Accessories:
FDCH221 Enclosure

P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue:	12 May 2022
Issue Date:	12 May 2022
Issue Number:	01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

© BRE Global Limited, 2021